

ADDENDUM No. 4 TO THE CONTRACT DOCUMENTS

Project: City of Dillingham Streets Rehabilitation

Addendum Issue Date: August 9, 2019

Issued for Bid Date: June 18, 2019

Bid Due Date: August 27, 2019 1:00pm (AK) --- **CHANGED THIS ADDENDUM** ---

Previous Addenda Issued: Addendum No. 1 (6-24-19), Addendum No. 2 (7-8-19), Addendum No. 3 (7-18-19)

Issued By: Michael Gemmell
PND Engineers, Inc.
1506 West 36th Avenue
Anchorage, Alaska 99503

Notice to Bidders:

Bidders must acknowledge receipt of this addendum prior to the date set for bid opening by the following method:

- (1) By acknowledging receipt of this addendum on the bid submitted.

The bid documents require acknowledgment individually of all addenda to the Drawings and/or Specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may be classified as not being a responsive bid. If, by virtue of this addendum it is desired to modify a bid already submitted, such modification may be made by fax provided such a fax refers to this addendum and is received prior to the opening date specified above.

The Contract Documents for the above project are amended as follows (all other terms and conditions remain unchanged):

ITEM 1

Section: *Invitation to Bids – Important Dates*

Change the Bid Due Date to **August 27, 2019** at 1:00 PM AK Standard Time.

BIDDER QUESTIONS:

Question: The plans show 2” foam board insulation. The state blue book states that it is to be installed with a minimum of 2 layers. Is this the case or will we be able to place one layer of 2” foam board?

Response: *The specification is correct. A minimum of 2 layers will be required.*

END OF ADDENDUM